

## Bend 90° Female-Female

**Manufacturing standards:** DVGW round tubes manufactured according to DIN-1988/2463 EN 10312 Tubes with DVGW TS 225 approval correspond to the requirements of DVGW worksheet W 541

**Certificates:** Standard supply in lengths of 6 m. We provide product certificates if required, according to the following standard: EN 10204/3.1.B or DIN 50049.

**Grades:** Austenitic grades types 304-L, 316-L

**Dimensions:** Manufactured in diameters from 15 mm to 108 mm. Wall thicknesses from 1 to 2 mm

**Applications:** DVGW W 541 tubes are used in the transport of drinking and chlorinated water up to 2 mg/l in water with AISI-316 L pipes, AISI-304 L quality is used in compressed air installations.



### Technical information

DN	Dimensiones		Art.
	Tubo Ø	L	
12	15	49	0102
15	18	53	0103
20	22	61	2004
25	28	72	2005
32	35	68	2006
40	42	80	2007
50	54	100	2008
65	76,1	153	2009
80	88,9	179	2010
100	108	222	2011